






## P-hal, Oerholm, NM

Lightweight roof


Light weight concrete walls

Concrete floor (no insulation)






Heat gain from roof heats up




# Temperature control in winter




Heating



### Climate records for the interior over one year.







# Humidity control in winter



Humidification in some periods



### Climate records for the interior over one year.




# New store for the Museum of cultural history in Ribe





The metal roof reflects the sun and prevents solar heating




 $AER = 0.03 h^{-1}$ 


# Temperature control

The floor has no insulation


The ground below gives temperature stability on an annual cycle




# Temperature gradient in February




# Measured temperatures inside and outside




# Ground temperature measured 2 m below surface




### The climate records for one year in the Ribe store




#### The temperature is 8 - 16 °C







#### The temperature is 10 - 16 °C and the RH is 55 - 60%



#### ...except when the dehumidifier was turned off





#### Dehumidification is always needed in summer























## Computer simulation of empty store, AER = 0,1 h<sup>-1</sup>



Unfired perforated clay bricks used for humidity buffer





	Climate control	Energy consumpt (pr. year)	Tempera ture	Relative humidity
Royal library, CPH	Full AC	30 kWh/m <sup>3</sup>	18-20°C	45-55%
P-hal Oerholm	Heating Hum cont	10 kWh/m³	10-25°C	50-60%
Værløse shelter	Dehumidi fication	6 kWh/m <sup>3</sup>	0-25°C	45-55%
Ribe store	Dehumidi fication	1,5 kWh/m³	7-15°C	45-55 %

	Climate control	Energy consumpt (pr. year)	Tempera ture	Relative humidity
Royal library, CPH	Full AC	30 kWh/m <sup>3</sup>	18-20°C	45-55%
P-hal Oerholm	Heating Hum cont	10 kWh/m³	10-25°C	50-60%
Værløse shelter	Dehumidi fication	6 kWh/m <sup>3</sup>	0-25°C	45-55%
Ribe store	Dehumidi fication	1,5 kWh/m³	7-15°C	45-55 %

	Climate control	Energy consumpt (pr. year)	Tempera ture	Relative humidity
Royal library, CPH	Full AC	30 kWh/m <sup>3</sup>	18-20°C	45-55%
P-hal Oerholm	Heating Hum cont	10 kWh/m³	10-25°C	50-60%
Værløse shelter	Dehumidi fication	6 kWh/m <sup>3</sup>	0-25°C	45-55%
Ribe store	Dehumidi fication	1,5 kWh/m³	7-15°C	45-55 %

	Climate control	Energy consumpt (pr. year)	Tempera ture	Relative humidity
Royal library, CPH	Full AC	30 kWh/m³	18-20°C	45-55%
P-hal Oerholm	Heating Hum cont	10 kWh/m³	10-25°C	50-60%
Værløse shelter	Dehumidi fication	6 kWh/m <sup>3</sup>	0-25°C	45-55%
Ribe store	Dehumidi fication	1,5 kWh/m³	7-15°C	45-55 %





















